



# TEACHING PERFORMANCE

Architectural Simulation in the Studio


Clarke Snell, RA

Associate Professor of Architecture, New York Institute of Technology


# CONTEXT

Architecture school curriculum is not in sync with contemporary building performance requirements.






























1. Vapour permeable skin
2. Rainscreen furring
3. Exterior mineral wool
4. ABS sheet floodproofing
5. Marine caulk and tape detail
6. Vapour open sheathing taped at joints
7. Stud frame with mineral wool
8. Continuous vapour open air barrier taped at seams
9. Interior insulated chase
10. Interior finish
11. Roof cavity insulation
12. I-Joist to limit break in insulation
13. Parapet frame and fascia
14. Typical roof membrane system with sloped insulation
15. Floor and wall structure designed to resist flood buoyancy forces
16. ABS floodproofing continuous under the floor system





# Local Law 97 – Building Emissions Limits

## Executive Summary

Local Law 97 of 2019, as amended by Local Law 147 of 2019 and Local Law 95 of 2020 (the “Law”) designates **annual building emissions intensity limits** which cap the amount of greenhouse gas emissions large buildings in New York City can produce. Buildings covered by the law will be required to report their greenhouse gas emissions intensity to the City for 2024 and every subsequent year. Starting in 2025, penalties will be assessed for exceeding a building’s emissions intensity limit for the prior year. These penalties are intended to be costlier than renovating the building to emit less. [Read Local Law 97](#).

## Overview

Under the Law, emissions are described in metric tons of carbon dioxide equivalent (tCO<sub>2</sub>e). Building emissions intensity is a measure of building emissions per square foot of building area (tCO<sub>2</sub>e/sf). Buildings’ emissions intensity limits will be calculated based on their occupancy types and fuel sources. Penalties of \$268 per tCO<sub>2</sub>e will be assessed for buildings that exceed their building emissions intensity limit. Visit the NYC Accelerator online to access the Local Law 97 Emissions Calculator and other resources: <https://www1.nyc.gov/site/nycaccelerator/index.page>. For additional information, visit the Urban Green Council online (<https://www.urbangreencouncil.org/content/projects/all-about-local-law-97>).

### What is covered

- Any building in New York City that exceeds 25,000 square feet
- Two or more buildings on the same tax lot that together exceed 50,000 square feet
- Two or more buildings held in condominium ownership that are governed by the same board of managers and that together exceed 50,000 square feet

### What isn’t covered

- Power generating facilities
- City-owned property
- New York City Housing Authority property
- Property owned by a Housing Development Fund Corporation
- Dedicated places of worship
- Certain types of condominiums of no more than three stories, as described in the Law

## Mechanics

Building emissions intensity limits will be calculated based on each calendar year’s twelve months of utility data, so buildings that are already subject to New York City’s benchmarking law ([Local Law 84](#) of 2009) will be familiar with the reporting obligations under Local Law 97.

## Compliance Dates

- (2024 – 2029)** An estimated 25% of covered buildings must reduce energy consumption to meet annual building emissions intensity limits established in 2024.
- (2030 – 2034)** An estimated 75% of covered buildings must reduce energy consumption to meet the stricter limits established in 2030. The annual building emissions limits align with the City’s goal of reducing greenhouse gas emissions citywide 40% by 2030.
- (Future dates)** No later than January 1, 2023, the City will establish annual building emissions intensity limits applicable for subsequent years.

Energy Star Portfolio Manager (ESPM) Property Types	Building Code (BC)	Section 28- 320.3.1 Item #	2024 – 2029 BC Building Emissions Intensity Limit (tCO <sub>2</sub> e/sf)	Section 28- 320.3.1 Item #	2024 – 2029 ESPM Building Emissions Factor (tCO <sub>2</sub> e/sf)
Adult Education	B	2	0.00846	3	0.00758
Ambulatory Surgical Center	B*	6	0.02381	7	0.01181
Automobile Dealership	B	2	0.00846	9	0.00675
Bank Branch	B	2	0.00846	8	0.00987
Bowling Alley	A-3	1	0.01074	5	0.00574
College/University	B	2	0.00846	8	0.00987
Convenience Store without Gas Station	M	7	0.01181	9	0.00675
Courthouse	A-3	1	0.01074	10	0.00426
Data Center	B	2	0.00846	6	0.02381
Distribution Center	S	10	0.00426	5	0.00574
Enclosed Mall	M	7	0.01181	1	0.01074
Financial Office	B	2	0.00846	2	0.00846
Fitness Center/Health Club/Gym	A-3	1	0.01074	8	0.00987
Food Sales	M	7	0.01181	7	0.01181
Food Service	M	7	0.01181	7	0.01181
Hospital (General Medical & Surgical)	I-2	6	0.02381	6	0.02381
Hotel	R-1	8	0.00987	8	0.00987
K-12 School	E	3	0.00758	9	0.00675
Laboratory	B*	6	0.02381	6	0.02381
Library	B	2	0.00846	9	0.00675
Lifestyle Center	M	7	0.01181	2	0.00846
Mailing Center/Post Office	B	2	0.00846	10	0.00426
Manufacturing/Industrial Plant	F	5	0.00574	3	0.00758
Medical Office	B	2	0.00846	1	0.01074
Movie Theater	A-1	1	0.01074	7	0.01181
Multifamily Housing	R-2	9	0.00675	9	0.00675
Museum	A-3	1	0.01074	7	0.01181
Non-Refrigerated Warehouse	S-1	10	0.00426	10	0.00426
Office	B	2	0.00846	3	0.00758
Other - Education	B	2	0.00846	2	0.00846
Other - Entertainment/Public Assembly	A-3	1	0.01074	8	0.00987
Other - Lodging/Residential	R-1	8	0.00987	3	0.00758
Other - Mall	M	7	0.01181	1	0.01074

# Local Law 97 – Building Emissions Limits

## Executive Summary

Local Law 97 of 2019, as amended by Local Law 147 of 2019 and Local Law 95 of 2020 (the “Law”) designates **annual building emissions intensity limits which cap the amount of greenhouse gas emissions large buildings in New York City can produce**. Buildings covered by the law will be required to report their greenhouse gas emissions intensity to the City for 2024 and every subsequent year. Starting in 2025, penalties will be assessed for exceeding a building’s emissions intensity limit for the prior year. These penalties are intended to be costlier than renovating the building to emit less. [Read Local Law 97](#).

## Overview

Under the Law, emissions are described in metric tons of carbon dioxide equivalent (tCO<sub>2</sub>e). Building emissions intensity is a measure of building emissions per square foot of building area (tCO<sub>2</sub>e/sf). Buildings’ emissions intensity limits will be calculated based on their occupancy types and fuel sources. Penalties of \$268 per tCO<sub>2</sub>e will be assessed for buildings that exceed their building emissions intensity limit. Visit the NYC Accelerator online to access the Local Law 97 Emissions Calculator and other resources: <https://www1.nyc.gov/site/nycaccelerator/index.page>. For additional information, visit the Urban Green Council online (<https://www.urbangreencouncil.org/content/projects/all-about-local-law-97>).

### What is covered

- Any building in New York City that exceeds 25,000 square feet
- Two or more buildings on the same tax lot that together exceed 50,000 square feet
- Two or more buildings held in condominium ownership that are governed by the same board of managers and that together exceed 50,000 square feet

### What isn’t covered

- Power generating facilities
- City-owned property
- New York City Housing Authority property
- Property owned by a Housing Development Fund Corporation
- Dedicated places of worship
- Certain types of condominiums of no more than three stories, as described in the Law

## Mechanics

Building emissions intensity limits will be calculated based on each calendar year’s twelve months of utility data, so buildings that are already subject to New York City’s benchmarking law ([Local Law 84](#) of 2009) will be familiar with the reporting obligations under Local Law 97.

## Compliance Dates

- (2024 – 2029)** An estimated 25% of covered buildings must reduce energy consumption to meet annual building emissions intensity limits established in 2024.
- (2030 – 2034)** An estimated 75% of covered buildings must reduce energy consumption to meet the stricter limits established in 2030. The annual building emissions limits align with the City’s goal of reducing greenhouse gas emissions citywide 40% by 2030.
- (Future dates)** No later than January 1, 2023, the City will establish annual building emissions intensity limits applicable for subsequent years.

Energy Star Portfolio Manager (ESPM) Property Types	Building Code (BC)	Section 28-320.3.1 Item #	2024 – 2029 BC Building Emissions Intensity Limit (tCO <sub>2</sub> e/sf)	Section 28-320.3.1 Item #	2024 – 2029 ESPM Building Emissions Factor (tCO <sub>2</sub> e/sf)
Adult Education	B	2	0.00846	3	0.00758
Ambulatory Surgical Center	B*	6	0.02381	7	0.01181
Automobile Dealership	B	2	0.00846	9	0.00675
Bank Branch	B	2	0.00846	8	0.00987
Bowling Alley	A-3	1	0.01074	5	0.00574
College/University	B	2	0.00846	8	0.00987
Convenience Store without Gas Station	M	7	0.01181	9	0.00675
Courthouse	A-3	1	0.01074	10	0.00426
Data Center	B	2	0.00846	6	0.02381
Distribution Center	S	10	0.00426	5	0.00574
Enclosed Mall	M	7	0.01181	1	0.01074
Financial Office	B	2	0.00846	2	0.00846
Fitness Center/Health Club/Gym	A-3	1	0.01074	8	0.00987
Food Sales	M	7	0.01181	7	0.01181
Food Service	M	7	0.01181	7	0.01181
Hospital (General Medical & Surgical)	I-2	6	0.02381	6	0.02381
Hotel	R-1	8	0.00987	8	0.00987
K-12 School	E	3	0.00758	9	0.00675
Laboratory	B*	6	0.02381	6	0.02381
Library	B	2	0.00846	9	0.00675
Lifestyle Center	M	7	0.01181	2	0.00846
Mailing Center/Post Office	B	2	0.00846	10	0.00426
Manufacturing/Industrial Plant	F	5	0.00574	3	0.00758
Medical Office	B	2	0.00846	1	0.01074
Movie Theater	A-1	1	0.01074	7	0.01181
Multifamily Housing	R-2	9	0.00675	9	0.00675
Museum	A-3	1	0.01074	7	0.01181
Non-Refrigerated Warehouse	S-1	10	0.00426	10	0.00426
Office	B	2	0.00846	3	0.00758
Other - Education	B	2	0.00846	2	0.00846
Other - Entertainment/Public Assembly	A-3	1	0.01074	8	0.00987
Other - Lodging/Residential	R-1	8	0.00987	3	0.00758
Other - Mall	M	7	0.01181	1	0.01074

Energy Star Portfolio Manager (ESPM) Property Types	Building Code (BC)	Section 28- 320.3.1 Item #	2024 – 2029 BC Building Emissions Intensity Limit (tCO2e/sf)	Section 28- 320.3.1 Item #	2024 – 2029 ESPM Building Emissions Factor (tCO2e/sf)
Museum	A-3	1	0.01074	7	0.01181
Non-Refrigerated Warehouse	S-1	10	0.00426	10	0.00426
Office	B	2	0.00846	3	0.00758
Other - Education	B	2	0.00846	2	0.00846
Other - Entertainment/Public Assembly	A-3	1	0.01074	8	0.00987
Other - Lodging/Residential	R-1	8	0.00987	3	0.00758
Other - Mall	M	7	0.01181	1	0.01074





1959

\$215K \$260K

GUGGENHEIM



1964

2003

\$232K \$1,369K

GENERAL MOTORS



1999

\$858K \$581K

BARCLAY'S

# NYC LOCAL LAW 97



constructed




remodeled



2024 fine



2030 fine




1905

??

\$0K \$94K


NEW YORK TECH



2017

\$0K \$0.6K

BLOOMBERG CENTER



2017

\$0 \$0

THE HOUSE AT CORNELL TECH

# PROBLEM

How do we teach aspiring architects to design to current building performance standards?

# OUR APPROACH

Teach performance simulation workflows that are tied to specific quantitative professional benchmarks.

Combine architectural simulations as a corequisite with comprehensive design studio so that workflows are immediately applied as inputs to an iterative design process.



# OUR APPROACH

Teach performance simulation workflows that are tied to specific quantitative professional benchmarks.


Combine architectural simulations as a corequisite with comprehensive design studio so that workflows are immediately applied as inputs to an iterative design process.

**IBC**<sup>®</sup>

INTERNATIONAL  
BUILDING  
CODE<sup>®</sup>




LIVING  
BUILDING  
CHALLENGE<sup>SM</sup>



Performance included in the studio project program. For this example:



Design a 45,000sf office building that meets:

1. Local building code
2. Living Building Challenge zero net water usage
3. LEED 4.1 Option 1 Daylighting (3 points)
4. NYC Local Law 97 compliance.





**Rhino**ceros







**Rhino****ceros**











Composite Sim Model.3dm (39 MB) - Rhino 7 Educational - [Perspective\*]

File Edit View Curve Surface SubD Solid Mesh Dimension Transform Tools Analyze Render Panels Help

Command: CSResultsPanel  
Command: CSResultsPanel  
Command: CSResultsPanel  
Command:

Standard CPlanes Display Viewport Layout Drafting Select Transform Curve Drawing Curve Tools Lines Surface Tools Solid Tools SubD Tools Mesh Tools Render Tools Drafting New in V7 PH Tools ClimateStudio

Perspective\*

CS Workflows CS Results

Result Files

Name	Tags	Date	Path
ze. natural ventilation		02/12/2024 08:09:38	C:\Users\M...
zd. glazing to 90.1		02/12/2024 08:06:14	C:\Users\M...
zc. infiltration to 90.1		02/12/2024 07:57:14	C:\Users\M...
zb. envelope to 90.1		02/12/2024 07:52:31	C:\Users\M...
za. conditioning to 90.1		02/12/2024 07:30:32	C:\Users\M...
z. loads to 90.1		02/12/2024 07:26:59	C:\Users\M...
y. 1960 baseline		02/12/2024 07:11:08	C:\Users\M...
x. 9W A19 bulb		02/11/2024 15:28:27	C:\Users\M...
w. 11W dl		02/11/2024 15:26:53	C:\Users\M...
v. 85W dl		02/11/2024 15:24:04	C:\Users\M...
u.view 55		02/11/2024 15:13:01	C:\Users\M...
t. view 35 shade S W 4'		02/11/2024 15:04:20	C:\Users\M...
s. split glazing view 50 dl 75		02/11/2024 14:28:27	C:\Users\M...
r. topright conference		02/11/2024 14:20:51	C:\Users\M...
q. vert shade S W		02/11/2024 14:07:35	C:\Users\M...
p. opaque no shade		02/11/2024 13:56:41	C:\Users\M...
o. no split glazing		02/11/2024 13:49:54	C:\Users\M...
n. same		02/11/2024 13:47:39	C:\Users\M...
m. split glazing		02/11/2024 13:42:16	C:\Users\M...
l. Light shelf inter S E		02/11/2024 13:37:15	C:\Users\M...
k. Glare		02/11/2024 13:32:56	C:\Users\M...
j. Shad NS vert W egg E none		02/11/2024 13:23:54	C:\Users\M...
i. Tviz 50		02/11/2024 10:50:53	C:\Users\M...
h. trip Tviz 71		02/11/2024 10:47:23	C:\Users\M...
g. rotate 30		02/11/2024 10:31:26	C:\Users\M...
f. con		02/11/2024 09:42:45	C:\Users\M...
e. S2 no con clear Tviz 88		02/11/2024 09:38:14	C:\Users\M...
d. Site 3 con		02/10/2024 17:19:26	C:\Users\M...
c2. Site 2 shading		02/17/2024 17:12:14	C:\Users\M...
c. Site 2 con		02/17/2024 11:33:27	C:\Users\M...
b. Site 1 con		02/10/2024 17:14:44	C:\Users\M...
a. Site 1 no con		02/10/2024 17:13:12	C:\Users\M...

Layers

Layer

Default

GRAPHICS

SITE

buildings

buildSHADE

coastline

contours

footprint

fp1

lines

major\_roads

minor\_roads

parks

paths

topography

water

MASSING

Site1

Site 2

Building

Roof

Shading

Shad2

Shad3

Shad4

Site 3

INFRASTRUCTURE

DAYLIGHT

ELECTRIC LIGHT

THERMAL MODEL

FACADE


Command: CSResultsPanel

Command: CSResultsPanel

Command: CSResultsPanel

Command:

Standard CPanes Display Viewport Layout Drafting Select Transform Curve Drawing Curve Tools Lines Surface Tools Solid Tools SubD Tools Mesh Tools Render Tools Drafting New in V7 PH Tools ClimateStudio



Perspective\*

Perspective Top Front Right


CS Workflows
CS Results

Radiation Map
New.York-Kennedy.Intl.AP,NY,USA
Materials: 2 on 5 layers
Surfaces: None visible
Import .cse file from Revit

Layer	Material
Default	None
SITE	None
buildings	Concrete Exterior Wall
buildSHADE	None
contours	None
lines	None
major_roads	None
minor_roads	None
parks	None
paths	None
topography	Dirty Asphalt
MASSING	None
Site 2	None
Shading	None
Shad2	Concrete Exterior Wall
Shad3	Concrete Exterior Wall
Shad4	Concrete Exterior Wall

Layers

Layer	C...	D...	Col...	Ma...
Default	✓			
GRAPHICS				
SITE				
buildings				
buildSHADE				
coastline				
contours				
footprint				
fp1				
lines				
major_roads				
minor_roads				
parks				
paths				
topography				
water				
MASSING				
Site1				
Site 2				
Building				
Roof				
Shading				
Shad2				
Shad3				
Shad4				
Site 3				
INFRASTRUCTURE				
DAYLIGHT				
ELECTRIC LIGHT				
THERMAL MODEL				
FACADE				





Composite Sim Model.3dm (39 MB) - Rhino 7 Educational - [Perspective\*]

File Edit View Curve Surface SubD Solid Mesh Dimension Transform Tools Analyze Render Panels Help

Command: CSResultsPanel  
Command: CSResultsPanel  
Command: CSResultsPanel

Standard CPlanes Display Viewport Layout Drafting Select Transform Curve Drawing Curve Tools Lines Surface Tools Solid Tools SubD Tools Mesh Tools Render Tools Drafting New in V7 PH Tools ClimateStudio

Perspective\*

CS WorkflowCS Results

Name	Tags	Date	Path
ze. natural ventilation		02/12/2024 08:09:38	C:\Users\VM
zd. glazing to 90.1		02/12/2024 08:06:14	C:\Users\VM
zc. infiltration to 90.1		02/12/2024 07:57:14	C:\Users\VM
zb. envelope to 90.1		02/12/2024 07:52:31	C:\Users\VM
za. conditioning to 90.1		02/12/2024 07:30:32	C:\Users\VM
z. loads to 90.1		02/12/2024 07:26:59	C:\Users\VM
y. 1960 baseline		02/12/2024 07:11:08	C:\Users\VM
x. 9W A19 bulb		02/11/2024 15:28:27	C:\Users\VM
w. 11W dl		02/11/2024 15:26:53	C:\Users\VM
v. 85W dl		02/11/2024 15:24:04	C:\Users\VM
u.view 55		02/11/2024 15:13:01	C:\Users\VM
t. view 35 shade S W 4'		02/11/2024 15:04:20	C:\Users\VM
s. split glazing view 50 dl 75		02/11/2024 14:28:27	C:\Users\VM
r. toplight conference		02/11/2024 14:20:51	C:\Users\VM
q. vert shade S W		02/11/2024 14:07:35	C:\Users\VM
p. opaque no shade		02/11/2024 13:56:41	C:\Users\VM
o. no split glazing		02/11/2024 13:49:54	C:\Users\VM
n. same		02/11/2024 13:47:39	C:\Users\VM
m. split glazing		02/11/2024 13:42:16	C:\Users\VM
l. Light shelf inter S E		02/11/2024 13:37:15	C:\Users\VM
k. Glass		02/11/2024 13:32:56	C:\Users\VM
j. Shad NS vert W egg E none		02/11/2024 13:23:54	C:\Users\VM
i. tviz 50		02/11/2024 10:50:53	C:\Users\VM
h. trip Tviz 71		02/11/2024 10:47:23	C:\Users\VM
g. rotate 30		02/11/2024 10:31:26	C:\Users\VM
f. con		02/11/2024 09:42:45	C:\Users\VM
e. S2 no con clear Tviz 88		02/11/2024 09:38:14	C:\Users\VM
d. Site 3 con		02/10/2024 17:19:26	C:\Users\VM
c2. Site 2 shading		02/17/2024 17:12:14	C:\Users\VM
c1. Site 2 no con		02/17/2024 11:33:27	C:\Users\VM
c. Site 2 con		02/10/2024 17:29:01	C:\Users\VM
b. Site 1 con		02/10/2024 17:14:44	C:\Users\VM

Layers

Layer

Default

> GRAPHICS

> SITE

> MASSING

> INFRASTRUCTURE

> DAYLIGHT

> Envelope

> Baseline

> Glazing Exterior

> Mullions

> Opaque added

> Split glazing

> Daylight

> View

> Interior

> Ceiling

> Core

> Floor

> Glazing Interior

> Grid - Core

> Grids

> Partitions

> Plan

> Other floors

> Roof

> Rotate 30

> Shading

> It1

> Shad1EggE

> Shad1EggW

> Shad1EW

> Shad1NS

> It2

> Shad2NS

> It3

> Shad3EggEW

> It4

Perspective Top Front Right



# OUR APPROACH


Teach performance simulation workflows that are tied to specific quantitative professional benchmarks.


Combine architectural simulations as a corequisite with comprehensive design studio so that workflows are immediately applied as inputs to an iterative design process.

CO-REQUISITE SYLLABUS DRAFT FOR ARCH 401 AND 413												
1st Day of Week	ARCH 401		ARCH 413									
	Class	Content	Class	Lecture and Modeling	Assign.	Description	Benchmark	Video Resource				
9/6	1	intro site visit	1	Intro: Why simulate?; benchmarking; building science review; climate studio overview; specific Rhino tips	Ex.1	Design a simple detached house that can be reconfigured as an apartment	—	<a href="#">link</a>				
9/13	2	precedent	2	Basics of daylighting; daylighting benchmarking; glazing intro; Model: Ex.2	Ex.2	Lighting 1: Iterate daylighting in the house and apartment	LEED 4.1	<a href="#">link</a>				
	3	program/site										
9/20	4	light/energy	3	Light vs. heat: sample modeling illustrating this dynamic; Model: Ex.3	Ex.3	Lighting 2: Iterate daylighting in a Medium Office Building	LEED 4.1	<a href="#">link</a>				
	5	energy/water/solar										
9/27	6	review with study models	4	Climate summary data review; Model: creating a context site; Discussion: using simulations to inform studio projects	Ex.4	Site: Daylighting studies on studio study models set on project context site	LEED 4.1	<a href="#">link</a>				
	7											
10/4	8	structure/materials	5	Intro to Grasshopper and custom parametric simulation; Model Ex.5	Ex.5	Systems 1: Simulate and iterate parametric façade options in Grasshopper	—	<a href="#">link</a>				
	9											
10/11	10	circulation/egress	6	Geometry of systems and circulation (HVAC, water, and egress); Model: Ex.6	Ex. 6	Systems 2: GH egress tool; Simulating water collection and usage	Living Building Challenge	<a href="#">link</a>				
	11											
10/18	12	project development	7	Electric lighting and controls basics; intro to skylights; Model: Ex.12	Ex. 7	Lighting 3: Simulate skylights, electric lighting, and controls	LEED 4.1	<a href="#">link</a>				
	13											
10/25	14	mid-review: program/structure/material	8	Review of IEQ and human comfort; Model Ex.8	Ex.8	Thermal 1: Iterate simple box with a single window: orientation, glazing, shading	—	<a href="#">link</a>				
	15	systems and energy										
11/1	16	project development	9	Review of envelope basics; Model Ex.9	Ex.9	Thermal 2: Iterate house/apartment through envelope and zoning variations.	ASHREA 90.1; Passive House; Local Law 97	<a href="#">link</a>				
	17											
11/8	18	envelope and energy - facade and detailing	10	Hi-performance design (thermal bridging, etc.); Model Ex.10	Ex.10	Thermal 3: Iterate larger building thorough envelope and zoning variations.	ASHREA 90.1; Passive House; Local Law 97	<a href="#">link</a>				
	19	project development										
11/15	20	review: passive/active energy: models	11	Review of renewables; intro to natural ventilation; Local Law 97 crash course; Model: Ex.11	Ex.11	Thermal 4: Simulate natural ventilation and PV; Benchmark runs to Local Law 97	ASHREA 90.1; Passive House; Local Law 97	<a href="#">link</a>				
	21	project development and detailing										
11/22	22	open space detailing		THANKSGIVING								
	23	THANKSGIVING										
11/29	24	synthesis	12	Review of mechanical systems: Model: Ex.12	Ex.12	Systems 3: Simulate mechanical systems for comparison; choose one and size	Local Law 97					
	25	comp: physical and digital energy model										
12/6	26	final redline pin up	13	Summary: why simulate: studio project work day	Ex.13	Integration: Review and integrate simulations to date; check-in with studio projects	Comprehensive Studio Program					
	27	production										
12/12	28	final review - MA	14	Final presentations	Ex. 13	Integration: Present simulation iterations from studio project. Focus: What changes were made based on iterative simulation process?	All					
	29	final review - OW										

# SIMS: SITE ANALYSIS

Change from visual, rule of thumb to quantitative analysis.

















winter  
solstice  
9 12 3



vernal  
equinox  
9 12 3




summer  
solstice  
9 12 3











winter  
solstice  
9 12 3





vernal  
equinox  
9 12 3





summer  
solstice  
9 12 3















CONTEXT  
BUILDINGS  
211 kBTU/sf/yr



**16% difference**




NO CONTEXT  
BUILDINGS  
252 kBTU/sf/yr



93  
baseline





124  
+25%





150  
+38%

WEST –  
NO SHADING





80 baseline



WEST –  
SHADING



43 - 47%





- 1 collection geometry from model
- 2 shading geometry from model
- 3 building usable square footage
- 4 panel efficiency
- 5 actual % of collection area that is PV






**N  
Y  
C**





COOLING  
jun/sept  
**24 hours**



HEATING  
jun/sept  
**24 hours**

CENTRAL PARK


LA GUARDIA

KENNEDY





COOLING  
jun/sept  
**8 hours**





HEATING  
oct/may  
**8 hours**



CENTRAL PARK

LA GUARDIA


KENNEDY











Menu

ICC DIGITAL CODES

Search across 2021 International Building Code ...

Sign In

All Codes » I-Codes

Legend Information

SECTIONS NOTES INSIGHTS

CHAPTER 10 MEANS OF EGRESS

SECTION 1001 ADMINISTRATION

[F] SECTION 1002 MAINTENANCE AND PLANS

SECTION 1003 GENERAL MEANS OF EGRESS

SECTION 1004 OCCUPANT LOAD

SECTION 1005 MEANS OF EGRESS SIZING

## SECTION 1005

### MEANS OF EGRESS SIZING

**1005.1 General.**

All portions of the *means of egress* system shall be sized in accordance with this section.

**Exception:** *Aisles* and *aisle accessways* in rooms or spaces used for assembly purposes complying with Section 1030.

**1005.2 Minimum width based on component.**

The minimum width, in inches (mm), of any *means of egress* components shall be not less than that specified for such component, elsewhere in this code.

**1005.3 Required capacity based on occupant load.**

The required capacity, in inches (mm), of the *means of egress* for any room, area, space or *story* shall be not less than that determined in accordance with Sections 1005.3.1 and 1005.3.2.

**1005.3.1 Stairways.**

The capacity, in inches, of means of egress *stairways* shall be calculated by multiplying the *occupant load* served by such *stairways* by a *means of egress* capacity factor of 0.3 inch (7.6 mm) per occupant. Where *stairways* serve more than one *story*, only the *occupant load* of each *story* considered individually shall be used in calculating the required capacity of the *stairways* serving the *story*.

**Exceptions:**


- For other than Group H and I-2 occupancies, the capacity, in inches, of means of egress *stairways* shall be calculated by

INTERNATIONAL BUILDING CODE®

ACCESS DOORWAYS

FEEDBACK

LIVE CHAT



Menu

ICC DIGITAL CODES®

Search across 2021 International Building Code (I...

Sign In

All Codes » I-Codes

Legend Information

SECTIONS NOTES INSIGHTS

CHAPTER 10 MEANS OF EGRESS

SECTION 1001 ADMINISTRATION

[F] SECTION 1002 MAINTENANCE AND PLANS

### TABLE 1004.5 MAXIMUM FLOOR AREA ALLOWANCES PER OCCUPANT

FUNCTION OF SPACE	OCCUPANT LOAD FACTOR <sup>a</sup>
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross

SECTION 1011 STAIRWAYS

1011.1 General.

1011.2 Width and capacity.

1011.3 Headroom.

1011.4 Walkline.

1011.5 Stair treads and risers.

1011.6 Stairway landings.

#### 1005.3.1 Stairways.

The capacity, in inches, of means of egress *stairways* shall be calculated by multiplying the *occupant load* served by such *stairways* by a *means of egress capacity factor* of 0.3 inch (7.6 mm) per occupant. Where *stairways* serve more than one *story*, only the *occupant load* of each *story* considered individually shall be used in calculating the required capacity of the *stairways* serving that *story*.

**Exceptions:**

- For other than Group H and I-2 occupancies, the capacity, in inches, of means of egress *stairways* shall be calculated by multiplying the *occupant load* served by such *stairways* by a *means of egress capacity factor* of 0.2 inch (5.1 mm) per occupant in buildings equipped throughout with an automatic sprinkler system installed in accordance with the requirements of Chapter 9.

1011.5 Stair treads and risers.

1011.6 Stairway landings.

1011.7 Stairway construction.

1011.8 Vertical rise.

1011.9 Curved stairways.

1011.10 Spiral stairways.



1011.11 Handrails.



#### 1011.5.2 Riser height and tread depth. P

Stair riser heights shall be 7 inches (178 mm) maximum and 4 inches (102 mm) minimum. The riser height shall be measured vertically between the *nosings* of adjacent *treads* or between the *stairway landing* and the adjacent *tread*. Rectangular tread depths shall be 11 inches (279 mm) minimum measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's *nosing*. *Winder* treads shall have a minimum tread depth of 11 inches (279 mm) between the vertical planes of the foremost projection of adjacent treads at the intersections with the walkline and a minimum tread depth of 10 inches (254 mm) within the clear width of the stair.

**Exceptions:**







## PRECIPITATION

Choose Climate

```
https://otterguytas-weather.s3.amazonaws.com/north_and_central_america_w-  
no_enigma_&/USA/NY/USA NY New.York.CiTy-  
Central.Park.94728_TMY/USA_NY-New.York.City-  
Central.Park.94728_TMY.zip
```

Click to Run

_weather_URL	monthly
download	ft/yr
_epw_map	in/yr

Inches/yr

46

months	
--------	--



kGallons

113

height (ft)



0.8

22

22

kGallons

building type

gal/mon Education ▼

floor area

months

~~Demand (kGal)~~

324

100

total used (kGal)

234

% Reduction

0.28

### of Cisterns

4

## IMPERATIVE

06

NET POSITIVE  
WATER



SCALE JUMPING PERMITTED

All projects must supply one hundred percent of the project's water needs through captured precipitation or other natural closed-loop water systems, and/or through recycling used project water, and all water must be purified as needed without the use of chemicals. No potable water may be used for non-potable uses. If captured precipitation is not adequate to supply the needs of the project after all possible efficiency measures are applied, connection to the municipal water system is allowed.

Scale jumping strategies are allowed with some limitations. For example, connecting to a community or municipal facility is allowed. Connection is also allowed where regulations prohibit onsite treatment,<sup>15</sup> or if the municipal system provides greater environmental benefit than onsite treatment. For all scale jumping, pump energy must be accounted for through renewable energy sources.

All projects must incorporate a resilience strategy to provide drinking water for at least a week for all regular building occupants through water storage onsite.

Affordable housing projects may use handprinting within the watershed in lieu of onsite collection or treatment systems to meet the project's water needs.

15 Refer to the v4.0 Water Petal Handbook for clarifications and exceptions, such as exceptions based on local health regulations.






**LIVING  
BUILDING  
CHALLENGE<sup>SM</sup>**

CERTIFIED - PITTSBURGH, PA  
OF FRICK ENVIRONMENTAL CENTER

Living Building Challenge™ 4.0







\* PROJECT RAINCATCHMENT CISTERN MODELER \*

## PRECIPITATION

- [illegible]

## WATER COLLECTION

4. Select collection area 

## CISTERN SPECS


6. Select height
- height (ft)
- ft 10
7. Percentage of volume holding water
- % 0.8
- 22 kGallons
- 90



## WATER USAGE



- 
8. Select building use: building type gal/mon Education
9. Select building use: floor area ksf 45
10. Select building use: months # 6
- Output: Total 324
- Output: % reduction 234
- Output: format 0.28

## CISTERNS FOR NET POSITIVE WATER

Final output = number of cisterns with defined specs required for the project to collect more water than it uses.









# SIMS: DAYLIGHTING

Change from the knee-jerk all glass façade (typical for architecture students) to a nuanced daylighting for health, energy efficiency and comfort.



**Option 1. Simulation: Spatial Daylight Autonomy and Annual Sunlight Exposure (1-3 points, 1-2 points Healthcare)**

Perform annual computer simulations for spatial daylight autonomy<sub>300/50%</sub> (sDA<sub>300/50%</sub>), and annual sunlight exposure<sub>1000,250</sub> (ASE<sub>1000,250</sub>) as defined in IES LM-83-12 for each regularly occupied space. Healthcare projects must use each regularly occupied space located in the perimeter area determined under EQ Credit Quality Views. Additionally, calculate the average sDA<sub>300/50%</sub> value for the total regularly occupied floor area.

For any regularly occupied spaces with ASE<sub>1000,250</sub> greater than 10%, identify how the space is designed to address glare.

Points are awarded according to Table 1.

**Table 1. Points for Option 1**

	<i>New Construction, Core and Shell, Schools, Retail, Data Centers, Warehouses and Distribution Centers, Hospitality</i>	Healthcare
The average sDA <sub>300/50%</sub> value for the regularly occupied floor area is at least <b>40%</b>	1 point	1 point
The average sDA <sub>300/50%</sub> value for the regularly occupied floor area is at least <b>55%</b>	2 points	2 points
The average sDA <sub>300/50%</sub> value for the regularly occupied floor area is at least <b>75%</b>	3 points	Exemplary performance

## Spatial Daylight Autonomy

(sDA) = enough daylight?

- regularly occupied spaces
- 300lux for 50% of time
- 75% of spaces (average)

## Annual Sunlight Exposure



(aSE) = too much?

- regularly occupied spaces
- 1,000lux for 250 hours/yr in 10% of space
- each space (not average)


## Annual Disturbing Glare

(sDG) = how about comfort?

- not specifically covered by LEED
- math tweaked by human comfort experiments
- once light inside, how do humans perceive it
- amount of light on work surface







CS Workflows

CS Results

Daylight Availability

LEED v4.1 Option 1

New York-Kennedy Intl. AP, NY, USA

Materials: 6 on 7 layers

Blinds: None visible

Areas: None visible

Tubular devices: None visible

Import .cse file from Revit

Layer	Material
Default	None
SITE	None
parks	None
minor_roads	None
buildings	Concrete Exterior Wall
major_roads	None
water	None
contours	None
coastline	None
topography	Dirty Asphalt
lines	None
paths	None
DAYLIGHT	None
Interior	None
Plan	None
Core	Beige Painted wall
Partitions	Beige Painted wall
Glazing Interior	Clear
Envelope	None
Baseline	None
Mullions	Aluminium Brown Window Mullion
Glazing Exterior	Solarban 90 (2) - Clear (Argon)
Other floors	None

Layers

Layer

C...

D...

Col..

Default

GRAPHICS

SITE

MASSING

INFRASTRUCTURE

DAYLIGHT

Envelope

Baseline

Glazing Exterior

Mullions

Opaque added

Split glazing

Daylight

View

Interior

Ceiling

Core

Floor

Glazing Interior

Grid - Core

Grids

Partitions

Plan

Other floors

Roof

Solid

Wire

Rotate 30

Shading

It1

Shad1EggE

Shad1EggW

Shad1EW


Shad1NS

It2


It3

It4

It5





BASELINE



ROTATED 30°


## ENOUGH?



\* ASE > 10% in one or more spaces. Glare control strategy must be explained.

average of all  
frequently occupied spaces

## TOO MUCH?





\* ASE > 10% in one or more spaces. Glare control strategy must be explained.


ID	Description	Tags	Sq.ft	Spacing[ft]	sDA	ASE	ASE.blinds	Avg.Lux	Blinds	DynamicGlass
E			1078	2.0	100.00 %	6.88 %	6.88 %	1431	N	N
Emeet			915	2.0	63.33 %	0.00 %	0.00 %	367	N	N
N			1080	2.0	100.00 %	0.00 %	0.00 %	1533	N	N
NE			1175	2.0	100.00 %	0.34 %	0.34 %	1930	N	N
NW			1164	2.0	100.00 %	37.41 %	37.41 %	3840	N	N
S			1092	2.0	100.00 %	59.47 %	59.47 %	4791	N	N
SE			1169	2.0	100.00 %	62.59 %	62.59 %	4893	N	N
SW			1158	2.0	100.00 %	77.82 %	77.82 %	6356	N	N
W			1101	2.0	100.00 %	51.74 %	51.74 %	3787	N	N
Wmeet			915	2.0	100.00 %	0.00 %	0.00 %	560	N	N

each space calculated individually











## COMFORT?



\* ASE > 10% in one or more spaces. Glare control strategy must be explained.








Single Tvis .87

Triple Tvis .71


Double Tvis .50

Shading Tvis .50

# LEED 4.1 DAYLIGHTING COMPLIANT




3\* credits  
74.8 %  
sDA<sub>300/50%</sub>  
12.4 %  
ASE<sub>1000,250</sub>



3\* credits  
74.8 %  
sDA<sub>300/50%</sub>  
12.4 %  
ASE<sub>1000,250</sub>


Shading Tvis .50



3\* credits  
784  
avg lux


almost 3,000 lux

WHAT ABOUT  
COMFORT?




10.1 %  
sDG (% views with Disturbing Glare > 5% of time)  
0 % Disturbing 5


areas of  
intolerable glare





4' southern overhang





add 4' internal light shelf

















**Tvis .50**  
**50% opaque envelope**




**Shading 4' horiz S&W**  
**Internal light shelf**




**Tubular skylights**  
**in conference rooms**




**Tvis .55/.74 (split glazing)**  
**Skylights in E&W offices**



**Tvis .87**



**Tvis .50**  
 shading 8' vert S; egg W  
 interior S&E light shelf




**Tvis .74/.55 (split glazing)**  
 50% opaque envelope  
 shading 4' S&W; tubular skylights



# SIMS: ELECTRIC LIGHTING

Change from lighting design being ignored to task-based illumination design studies. Outputs also feed the energy analysis simulation.





### work plane illuminance target lux



Mechanical / Electrical Room	20-50 FC	200-500 lux
Office - Open	30-50 FC	300-500 lux
Office - Private / Closed	30-50 FC	300-500 lux

design lighting layout and fixtures to deliver target lux


information informs lighting power density in energy use analysis



circular downlight; 6", 85W, 5788 lm  
**2,849 lux (mean)**



circular downlight; 4", 11W, 965 lm  
**485 lux (mean)**



A19 bulb; 9W, 860 lm  
**245 lux (mean)**

# SIMS: ENERGY USE

Change from an R-value chart to a full system based project site EUI and carbon footprint analysis.



**2021 International Energy Conservation Code (IECC) and ANSI/ASHRAE/IES Standard 90.1-2019**

Version: Jan 2021

Codes / I-Codes / 2021 International Energy Conservation Code (IECC) and ANSI/ASHRAE/IES Standard 90.1-2019

**REQUIREMENTS, R-VALUE METHOD<sup>a</sup>**

CLIMATE ZONE	0 AND 1		2		3		4 EXCEPT MARINE	
	All other	Group R	All other	Group R	All other	Group R	All other	Group R
<b>Roofs</b>								
Insulation entirely above roof deck	R-20ci	R-25ci	R-25ci	R-25ci	R-25ci	R-25ci	R-30ci	R-30ci
Metal buildings <sup>b</sup>	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS
Attic and other	R-38	R-38	R-38	R-38	R-38	R-38	R-49	R-49
<b>Walls, above grade</b>								
Mass <sup>f</sup>	R-5.7ci <sup>c</sup>	R-5.7ci <sup>c</sup>	R-5.7ci <sup>c</sup>	R-7.6ci	R-7.6ci	R-9.5ci	R-9.5ci	R-11.4ci
Metal building	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-14ci
Metal framed	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci
Wood framed and other	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20

**CONTENTS**

- Chapter 4 [CE] Commercial Energy Efficiency
  - Section C401 General
  - Section C402 Building Envelope Requirements
    - C402.1 General.
      - C402.1.1 Low-Energy Buildings and Greenhouses.
      - C402.1.2 Equipment Buildings.
      - C402.1.3 Insulation Component R-Value-Based Method. R**
      - C402.1.4 Assembly U-Factor, C-Factor or F-Factor-Based Method. U C F
        - C402.1.4.1 Roof/Ceiling Assembly.
        - C402.1.4.2 Thermal Resistance of Cold-Formed Steel Walls.
        - C402.1.5 Component Performance Alternative.
      - C402.2 Specific Building Thermal Envelope Insulation Requirements.
        - C402.2.1 Roof Assembly.
        - C402.2.2 Above-Grade Walls.

Library Browser

Curve Drawing Curve Tools Lines Surface Tools

Opaque Constructions Glazing Constructions Glass Panes Gas Layers

Zone Settings

Loads Conditioning Envelope Settings

Constructions

Roof: 90.1-2019 Nonresidential CZ 4 Exterior Roof (Mass)  
U-Value[BTU/(h·ft²·°F)] = 0.031 | Thermal Capacitance[BTU/(h·ft²)] = 23.128

Facade: 90.1-2019 Residential CZ 4 Exterior Wall (Mass)  
U-Value[BTU/(h·ft²·°F)] = 0.083 | Thermal Capacitance[BTU/(h·ft²)] = 26.621

Partition: A413.1960.Partition  
U-Value[BTU/(h·ft²·°F)] = 0.47 | Thermal Capacitance[BTU/(h·ft²)] = 25.497

Slab: MediumOffice-4A\_INT-FLOOR-TOPSIDE

Constructions

Outside / Top

2

90.1-2019 Nonresidential CZ 4 Exterior  
U-Value[BTU/(h·ft²·°F)] = 0.031  
R-Value[ft²·°F/BTU] = 31.266  
Thermal Capacitance[BTU/(h·ft²)] = 23.128  
Embodied Energy[kCal/ft²] = 219464.389  
Embodied Carbon[lbCO₂/ft²] = 13.606

Layers: (Outside - Inside)

- Vaporpermeable Felt 0.01 [ft]
- XPS Board 0.593 [ft]
- Concrete 0.666 [ft]
- Acoustic Tile 0.016 [ft]

Inside / Bottom

Flow 0.05

Any Type Any Standard

Name	Type	Standard	Climate
90.1-2019 Nonresidential CZ 2 Ground Wall (M Facade)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Floor (N ExteriorFloor)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Roof (N Roof)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Wall (M Facade)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Ground Slab (M GroundFloor)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Ground Wall (M Facade)	ASHRAE 90.1 2019	Clir	

Vertex Project Disable

Grid Snap Ortho Planar Osnap

### 2021 International Energy Conservation Code (IECC) and ANSI/ASHRAE/IES Standard 90.1-2019

Version: Jan 2021

**CONTENTS**


- Chapter 4 [CE] Commercial Energy Efficiency
  - Section C401 General
  - Section C402 Building Envelope Requirements
    - C402.1 General.
      - C402.1.1 Low-Energy Buildings and Greenhouses.
      - C402.1.2 Equipment Buildings.
      - C402.1.3 Insulation Component R-Value-Based Method. R**
      - C402.1.4 Assembly U-Factor, C-Factor or F-Factor-Based Method. U C F
        - C402.1.4.1 Roof/Ceiling Assembly.
        - C402.1.4.2 Thermal Resistance of Cold-Formed Steel Walls.
        - C402.1.5 Component Performance Alternative.
      - C402.2 Specific Building Thermal Envelope Insulation Requirements.
        - C402.2.1 Roof Assembly.
        - C402.2.2 Above-Grade Walls.

Codes / I-Codes /

2021 International Energy Conservation Code (IECC) and ANSI/ASHRAE/IES Standard 90.1-2019

**REQUIREMENTS, R-VALUE METHOD<sup>a</sup>**

CLIMATE ZONE	0 AND 1		2		3		4 EXCEPT MARINE	
	All other	Group R	All other	Group R	All other	Group R	All other	Group R
<b>Roofs</b>								
Insulation entirely above roof deck	R-20ci	R-25ci	R-25ci	R-25ci	R-25ci	R-25ci	<b>R-30ci</b>	R-30ci
Metal buildings <sup>b</sup>	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS
Attic and other	R-38	R-38	R-38	R-38	R-38	R-38	R-49	R-49
<b>Walls, above grade</b>								
Mass <sup>f</sup>	R-5.7ci <sup>c</sup>	R-5.7ci <sup>c</sup>	R-5.7ci <sup>c</sup>	R-7.6ci	R-7.6ci	R-9.5ci	R-9.5ci	R-11.4ci
Metal building	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-14ci
Metal framed	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci
Wood framed and other	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20



**Zone Settings**

Loads Conditioning Envelope Settings

Constructions

- Roof: 90.1-2019 Nonresidential CZ 4 Exterior Roof (Mass)**  
U-Value[BTU/(h<sup>2</sup>·F·ft<sup>2</sup>)] = 0.031 | Thermal Capacitance[BTU/(h<sup>2</sup>·F)] = 23.128
- Facade: 90.1-2019 Residential CZ 4 Exterior Wall (Mass)  
U-Value[BTU/(h<sup>2</sup>·F·ft<sup>2</sup>)] = 0.083 | Thermal Capacitance[BTU/(h<sup>2</sup>·F)] = 26.621
- Partition: A413.1960.Partition  
U-Value[BTU/(h<sup>2</sup>·F·ft<sup>2</sup>)] = 0.47 | Thermal Capacitance[BTU/(h<sup>2</sup>·F)] = 25.497
- Slab: MediumOffice-4A\_INT-FLOOR-TOPSIDE

Outside / Top

**90.1-2019 Nonresidential CZ 4 Exterior**


U-Value[BTU/(h<sup>2</sup>·F·ft<sup>2</sup>)] = 0.031  
R-Value[ft<sup>2</sup>·F·h/BTU] = 31.266  
Thermal Capacitance[BTU/(h<sup>2</sup>·F)] = 23.128  
Embodied Energy[kCal/ft<sup>2</sup>] = 219464.389  
Embodied Carbon[lbCO<sub>2</sub>/ft<sup>2</sup>] = 13.606

Layers: (Outside - Inside)

- Vaporpermeable Felt 0.01 [ft]
- XPS Board 0.593 [ft]
- Concrete 0.666 [ft]
- Acoustic Tile 0.016 [ft]


Inside / Bottom

Name	Type	Standard	Climate
90.1-2019 Nonresidential CZ 2 Ground Wall (M Facade)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Floor (N ExteriorFloor)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Roof (N Roof)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Exterior Wall (M Facade)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Ground Slab (M GroundFloor)	ASHRAE 90.1 2019	Clir	
90.1-2019 Nonresidential CZ 3 Ground Wall (M Facade)	ASHRAE 90.1 2019	Clir	



**iPHA**

**PHIUS**



<b>840</b>	<b>520</b>	<b>313</b>	<b>None</b>	<b>284</b>
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

**Loads** | **Conditioning** | **Envelope** | **Settings**

Medium Office | Program

MediumOffice | UseType

**People** ☒ On

0.0538004648360162 | People Density [P/m<sup>2</sup>]

1.2 | Metabolic Rate [met]

OfficeMedium BLDG\_OCC\_SCH | Occupancy Schedule

AirSpeed 0 | Airspeed Schedule [m/s]

Dynamic Clothing Model ASHRAE55 | Clothing [clo]

**Equipment** ☒ On

7.42446414737023 | Equipment Power Density [W/m<sup>2</sup>]

OfficeMedium BLDG\_EQUIP\_SCH\_2013 | Equipment Availability Schedule

**Lighting** ☒ On






6.88645949901007 | Lighting Power Density [W/m<sup>2</sup>]

OfficeMedium BLDG\_LIGHT\_SCH\_2013 | Lights Availability Schedule

376.603253852113 | Illuminance Target [Lux]


Off | DimmingType

**Hot Water** ☒ On








## ENERGY USE: BASELINE “1960” BUILDING






430	247	325	None	284
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

Loads Conditioning Envelope Settings  
 Medium Office Program  
 MediumOffice UseType  
 People On  
 0.0538004648360162 People Density [P/m<sup>2</sup>]  
 1.2 Metabolic Rate [met]  
 OfficeMedium BLDG\_OCC\_SCH Occupancy Schedule  
 AirSpeed 0 Airspeed Schedule [m/s]  
 Dynamic Clothing Model ASHRAE55 Clothing [clo]  
 Equipment On  
 7.42446414737023 Equipment Power Density [W/m<sup>2</sup>]  
 OfficeMedium BLDG\_EQUIP\_SCH\_2013 Equipment Availability Schedule  
 Lighting On  
 6.88645949901007 Lighting Power Density [W/m<sup>2</sup>]  
 OfficeMedium BLDG\_LIGHT\_SCH\_2013 Lights Availability Schedule  
 376.603253852113 Illuminance Target [Lux]  
 Off Dimming Type  
 Hot Water On



## ENERGY USE: LOADS TO 90.1



350	200	283	None	284
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

**Heating** ☒ On

OfficeMedium HTGSETP\_SCH\_YES\_OPTIMUM Schedule HeatingSetpoint [°C]

AllOn HeatingSchedule [Schedule name]

30 Max Heat Supply Air Temp [°C]

NoLimit HeatingLimitType [enum]

100 MaxHeatingCapacity [W/m<sup>2</sup>]

100 MaxHeatFlow [m<sup>3</sup>/s/m<sup>2</sup>]

0.81 HeatingCOP

**Cooling** ☒ On

OfficeMedium CLGSETP\_SCH\_YES\_OPTIMUM Schedule CoolingSetpoint [°C]

AllOn CoolingSchedule [Schedule name]

18.333333333333333 Min Cool Supply Air Temp [°C]

NoLimit CoolingLimitType [enum]

100 MaxCoolingCapacity [W/m<sup>2</sup>]

100 MaxCoolFlow [m<sup>3</sup>/s/m<sup>2</sup>]

3.4 CoolingCOP

**Humidity Control** ☐ Off

**Mechanical Ventilation** ☒ On

0 Min Fresh Air Person [L/s/p]

0.431646861649681 Min Fresh Air Area [L/s/m<sup>2</sup>]

AllOn MechVentSchedule [Schedule name]

Enthalpy Heat Recovery Type [enum]






0.7 Heat Recovery Efficiency Sensible [0-1]

0.5 Heat Recovery Efficiency Latent [0-1]



NoEconomizer Economizer Type [enum]

☐ Turn On EMS Fan Energy

1000 Fan Pressure Rise [Pa]



## ENERGY USE: CONDITIONING TO 90.1



Loads

Conditioning

Envelope

Settings

Constructions

Roof: 90.1-2019 Nonresidential CZ 4 Exterior Roof (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.177 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 472.784

Facade: 90.1-2019 Residential CZ 4 Exterior Floor (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.273 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 301.273

Partition: A413.1960.Partition

U-Value[W/(m<sup>2</sup>·K)] = 2.672 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 521.208

Slab: MediumOffice-4A\_INT-FLOOR-TOPSIDE

U-Value[W/(m<sup>2</sup>·K)] = 1.577 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 190.451

External Floor: 90.1-2019 Nonresidential CZ 4 Exterior Floor (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.303 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 298.663

Ground Slab: 90.1-2019 Nonresidential CZ 4 Ground Slab (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.692 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 472.04

Ground Wall: 90.1-2019 Nonresidential CZ 4 Ground Wall (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.117 | Thermal Capacitance[kJ/(K·m<sup>2</sup>)] = 476.67

Additional Internal Mass

Off

Infiltration






On

Flow / Exterior Area

0.0018789333977692



InfiltrationFlowExtArea [m3/s/m2]

Advanced Options...



## ENERGY USE: ENVELOPE TO 90.1





Loads

Conditioning

Envelope

Settings

Constructions

Roof: 90.1-2019 Nonresidential CZ 4 Exterior Roof (Mass)

U-Value[W/(m²·K)] = 0.177 | Thermal Capacitance[kJ/(K·m²)] = 472.784

Facade: 90.1-2019 Residential CZ 4 Exterior Wall (Mass)

U-Value[W/(m²·K)] = 0.47 | Thermal Capacitance[kJ/(K·m²)] = 544.178

Partition: A413.1960.Partition

U-Value[W/(m²·K)] = 2.672 | Thermal Capacitance[kJ/(K·m²)] = 521.208

Slab: MediumOffice-4A\_INT-FLOOR-TOPSIDE

U-Value[W/(m²·K)] = 1.577 | Thermal Capacitance[kJ/(K·m²)] = 190.451

External Floor: 90.1-2019 Nonresidential CZ 4 Exterior Floor (Mass)

U-Value[W/(m²·K)] = 0.303 | Thermal Capacitance[kJ/(K·m²)] = 298.663

Ground Slab: 90.1-2019 Nonresidential CZ 4 Ground Slab (Mass)

U-Value[W/(m²·K)] = 0.692 | Thermal Capacitance[kJ/(K·m²)] = 472.04

Ground Wall: 90.1-2019 Nonresidential CZ 4 Ground Wall (Mass)

U-Value[W/(m²·K)] = 0.117 | Thermal Capacitance[kJ/(K·m²)] = 476.67

Additional Internal Mass

Off






Infiltration

On


Flow / Exterior Area

0.000299613703968602

InfiltrationFlowExtArea [m3/s/m2]








## ENERGY USE: INFILTRATION TO 90.1




108	65	57	62%	284
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

Loads Conditioning Envelope Settings  
 Medium Office Program  
 MediumOffice UseType  
 People On  
 0.0538004648360162 People Density [P/m<sup>2</sup>]  
 1.2 Metabolic Rate [met]  
 OfficeMedium BLDG\_OCC\_SCH Occupancy Schedule  
 AirSpeed 0 Airspeed Schedule [m/s]  
 Dynamic Clothing Model ASHRAE55 Clothing [clo]  
 Equipment On  
 7.42446414737023 Equipment Power Density [W/m<sup>2</sup>]  
 OfficeMedium BLDG\_EQUIP\_SCH\_2013 Equipment Availability Schedule  
 Lighting On  
 6.88645949901007 Lighting Power Density [W/m<sup>2</sup>]  
 OfficeMedium BLDG\_LIGHT\_SCH\_2013 Lights Availability Schedule  
 376.603253852113 Illuminance Target [Lux]  
 Off Dimming Type  
 Hot Water On



## ENERGY USE: GLAZING TO 90.1








101	61	55	64%	284
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

☒ Mechanical Ventilation  
☐ Natural Ventilation


Min Fresh Air Person [L/s/p]: 0  
 Min Fresh Air Area [L/s/m<sup>2</sup>]: 0.431646861649681  
 MechVentAvailNYC5985  
 MechVentSchedule [Schedule name]: Enthalpy  
 Heat Recovery Type [enum]: 0.7  
 Heat Recovery Efficiency Sensible [0-1]: 0.5  
 Heat Recovery Efficiency Latent [0-1]: NoEconomizer  
 Economizer Type [enum]: Turn On EMS Fan Energy  
 Fan Pressure Rise [Pa]: 1000

Nat Vent SetPoint [°C]: 22  
 NatVentAvailNYC5985  
 Natural Ventilation Schedule: 0  
 Nat Vent Min Out Air Temp [°C]: 30  
 Nat Vent Max Out Air Temp [°C]: 90  
 Nat Vent Max Relative Hum [RH%]: Natural Ventilation  
☒ Stack Driven Flow ☐ Crossventilation



## ENERGY USE: NATURAL VENTILATION





84	51	39	70%	284
Site EUI	Op. Carbon	Energy Cost	Saved	Baseline EUI
kWh/m <sup>2</sup>	kgCO <sub>2</sub> /m <sup>2</sup>	\$/m <sup>2</sup>	Vs. Baseline	kWh/m <sup>2</sup>

Hot Water ☐

3 COP [unitless]

10 Inlet Water Temperature [°C]






60 Water Supply Temperature [°C]

OfficeMedium BLDG\_SWH\_SCH Water Schedule


0.000416395378768378 Flow Rate Per Person [m<sup>3</sup>/h/P]

Constructions

Roof: PHROOF_UVal_0.2_Mass	U-Value[W/(m <sup>2</sup> ·K)] = 0.057   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 483.432
Facade: 413.PH4a.ExtWall	U-Value[W/(m <sup>2</sup> ·K)] = 0.111   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 472.379
Partition: A413.1960.Partition	U-Value[W/(m <sup>2</sup> ·K)] = 2.672   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 521.208
Slab: MediumOffice-4A_INT-FLOOR-TOPSIDE	U-Value[W/(m <sup>2</sup> ·K)] = 1.577   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 190.451
External Floor: 413.PH4a.ExtWall	U-Value[W/(m <sup>2</sup> ·K)] = 0.111   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 472.379
Ground Slab: 90.1-2019 Nonresidential CZ 4 Ground Slab (Mass)	U-Value[W/(m <sup>2</sup> ·K)] = 0.692   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 472.04
Ground Wall: 90.1-2019 Nonresidential CZ 4 Ground Wall (Mass)	U-Value[W/(m <sup>2</sup> ·K)] = 0.117   Thermal Capacitance[J/(K·m <sup>2</sup> )] = 476.67



## ENERGY USE: OPTIMIZATION TWEAKS





Zone Settings

Loads Conditioning Envelope Settings

Carbon and Cost factors



0.5558	HeatingCO2 [Kg/kWh]
0.93	HeatingCost [\$ /kWh]
0.637	CoolingCO2 [Kg/kWh]
0.22	CoolingCost [\$ /kWh]
0.5558	HotWaterCO2 [Kg/kWh]
0.93	HotWaterCost [\$ /kWh]
0.637	ElectricityCO2 [Kg/kWh]
0.22	ElectricityCost [\$ /kWh]

No change in form required to achieve considerable reduction in operational energy footprint



840	520	313	None	284
Site EUI kWh/m²	Op. Carbon kgCO <sub>2</sub> /m²	Energy Cost \$/m²	Saved Vs. Baseline	Baseline EUI kWh/m²

BASELINE OLD SCHOOL



84	51	39	70%	284
Site EUI kWh/m²	Op. Carbon kgCO <sub>2</sub> /m²	Energy Cost \$/m²	Saved Vs. Baseline	Baseline EUI kWh/m²

90.1 PLUS TWEAKS





# SIMS: ENERGY BALANCE

Change from no consideration to a quantified analysis of energy and carbon footprint in the context of NYC Local Law 97 compliance.








Energy Star Portfolio Manager (ESPM) Property Types	Building Code (BC)	Section 28- 320.3.1 Item #	2024 – 2029 BC Building Emissions Intensity Limit (tCO2e/sf)	Section 28- 320.3.1 Item #	2024 – 2029 ESPM Building Emissions Factor (tCO2e/sf)
Museum	A-3	1	0.01074	7	0.01181
Non-Refrigerated Warehouse	S-1	10	0.00426	10	0.00426
Office	B	2	0.00846	3	0.00758
Other - Education	B	2	0.00846	2	0.00846
Other - Entertainment/Public Assembly	A-3	1	0.01074	8	0.00987
Other - Lodging/Residential	R-1	8	0.00987	3	0.00758
Other - Mall	M	7	0.01181	1	0.01074




GEOM / EFFICIENCY / SHAD







PANELS AT 30° TILT





NO CONTEXT SHADING




CONTEXT SHADING




GEOM / EFFICIENCY / SHAD



PANELS AT 30° TILT



NO CONTEXT SHADING



CONTEXT SHADING

## NYC LL97

Energy Star Portfolio Manager (ESPM) Property Types	Building Code (BC)	Section 28- 320.3.1 Item #	2024 – 2029 BC Building Emissions Intensity Limit (tCO <sub>2</sub> e/sf)	Section 28- 320.3.1 Item #	2024 – 2029 ESPM Building Emissions Factor (tCO <sub>2</sub> e/sf)
Museum	A-3	1	0.01074	7	0.01181
Non-Refrigerated Warehouse	S-1	10	0.00426	10	0.00426
Office	B	2	0.00846	3	0.00758
Other - Education	B	2	0.00846	2	0.00846
Other - Entertainment/Public Assembly	A-3	1	0.01074	8	0.00987
Other - Lodging/Residential	R-1	8	0.00987	3	0.00758
Other - Mall	M	7	0.01181	1	0.01074

## CONVERSION

Building CO <sub>2</sub> e Limits (lbCO <sub>2</sub> /sf/a)							
Code Occup	2024		2030		35-49	2050	
	tCO <sub>2</sub> e/sf	lbCO <sub>2</sub> /sf	tCO <sub>2</sub> e/sf	lbCO <sub>2</sub> /sf		tCO <sub>2</sub> e/sf	lbCO <sub>2</sub> /sf
A	0.01074	23.68	0.0042	9.26	TBD	0.0014	3.09
B	0.00846	18.65	0.00453	9.99		0.0014	3.09
E	0.00758	16.71	0.00344	7.58		0.0014	3.09
I	0.01136	25.09	0.00598	13.18		0.0014	3.09
F	0.00574	12.65	0.00167	3.68		0.0014	3.09
M	0.01181	26.04	0.00403	8.88		0.0014	3.09
R2	0.00675	14.88	0.00407	8.97		0.0014	3.09
S/U	0.00426	9.39	0.0011	2.43		0.0014	3.09

LL97 COMPLIANCE WORKSHEET																				
Sim #	Allowed Operation Carbon (lbCO <sub>2</sub> /sf)					Design			SiteEUI				Operational Carbon Emissions				Compliance			
	Occup	2024	2029	2035	2050	Run Description	Build area (sf)	LL97 applies	Usage		PV	Total	From Loads		Coeff	Total CO <sub>2</sub>				
									(kWh/m <sup>2</sup> )	kWh			(kBTU/sf)	(kBTU/sf)						
y	B	18.65	9.99	TBD	3.09	1960 baseline	43,875	YES	840	3,428,372	267	267	520	106	0.40	106.42	NO	NO	TBD	NO
z	B	18.65	9.99	TBD	3.09	90.1 loads	43,875	YES	430	1,755,000	136	136	247	51	0.37	50.55	NO	NO	TBD	NO
za	B	18.65	9.99	TBD	3.09	90.1 conditioning	43,875	YES	350	1,428,488	111	111	200	41	0.37	40.93	NO	NO	TBD	NO
zb	B	18.65	9.99	TBD	3.09	90.1 envelope	43,875	YES	231	942,802	73	73	134	27	0.37	27.42	NO	NO	TBD	NO
zc	B	18.65	9.99	TBD	3.09	90.1 infiltration	43,875	YES	123	502,012	39	39	73	15	0.38	14.94	YES	NO	TBD	NO
zd	B	18.65	9.99	TBD	3.09	90.1 glazing	43,875	YES	108	440,791	34	34	65	13	0.39	13.30	YES	NO	TBD	NO
ze	B	18.65	9.99	TBD	3.09	natural ventilation	43,875	YES	101	412,221	32	32	61	12	0.39	12.48	YES	NO	TBD	NO
zf	B	18.65	9.99	TBD	3.09	HWHP PH envelope	43,875	YES	84	342,837	27	27	51	10	0.39	10.44	YES	NO	TBD	NO
zf	B	18.65	9.99	TBD	3.09	add PV	43,875	YES	84	342,837	27	18	9	51	10	3.39	YES	YES	TBD	NO
zf	B	18.65	9.99	TBD	3.09	improve PV	43,875	YES	84	342,837	27	20	7	51	10	2.61	YES	YES	TBD	YES


IS IT  
LEGAL?



## BUILDING CODE



## CLIMATE STUDIO ENERGY USE



## PV ANALYSIS





# RESULTS: STUDENT WORK


We ran the course for the first time last Fall semester as a co-requisite with the 4<sup>th</sup> comprehensive studio. This pairing is now required for all undergrad and grad professional architecture degree students.

# BED-STUY COMMUNITY CENTER

RENDERING: STREET VIEW





# BED-STUY COMMUNITY CENTER PLANS





# BED-STUY COMMUNITY CENTER

## SECTIONS




# BED-STUY COMMUNITY CENTER

## RENDERED ELEVATIONS



NORTH




EAST



# BED-STUY COMMUNITY CENTER


## PHYSICAL MODEL



45

# BED-STUY COMMUNITY CENTER

PHYSICAL MODEL: SECTION




50



# COMPREHENSIVE SECTION (SUMMER)


SCALE: 1/8" = 1'-0"




# COMPREHENSIVE SECTION (EQUINOX)

SCALE: 1/8" = 1'-0"

COMPOSITE SLAB O/ CLT PANELS







# DETAIL WALL SECTION (SOUTH)

BED-STUY COMMUNITY CENTER | BROOKLYN, NY | SABRINA INNAMORATO

SCALE: 1/4" = 1'-0"





ROOF ASSEMBLY	R VALUE / INCH	U VALUE	THICKNESS	R VALUE
EXTERIOR AIR SURFACE	0.17	5.88	1.00	0.17
STANDING SEAM METAL CLADDING	1.00	1.00	1.00	1
WATERPROOFING MEMBRANE	0.15	53.33	0.125	0.02
RIGID INSULATION BOARD	4.00	0.05	5.50	22
VAPOR BARRIER MEMBRANE	0.00	0.00	0.125	0.00
CONCRETE COMPOSITE LAYER	0.125	4.00	2.00	0.25
5-PLY CLT PANEL	1.00	0.10	10.00	10
INTERIOR AIR SURFACE	0.61	1.64	1.00	0.61
				34


PANELIZED WOOD RAINSCREEN WITH METAL FASTENERS

WALL ASSEMBLY	R VALUE / INCH	U VALUE	THICKNESS	R VALUE
EXTERIOR AIR SURFACE	0.17	5.88	1.00	0.17
WATER PROOFING MEMBRANE	0.15	53.33	0.125	0.02
RIGID INSULATION	4.00	0.05	5.50	22.00
VAPOR BARRIER MEMBRANE	0.00	0.00	0.125	0.00
5-PLY CLT PANEL	1.00	0.10	10.00	10
INTERIOR AIR SURFACE	0.68	1.47	1.00	0.68
				33



# COMPREHENSIVE SECTION (SUMMER)


SCALE: 1/8" = 1'-0"




# COMPREHENSIVE SECTION (EQUINOX)

SCALE: 1/8" = 1'-0"


COMPOSITE SLAB O/ CLT PANELS




winter solstice  
noon



summer solstice  
noon




# ORIGINAL DESIGN











0 credits	38.4 % sDA <sub>300/50%</sub>	13.1 % ASE <sub>1000,250</sub>	889 avg lux	- blinds open
--------------	----------------------------------	-----------------------------------	----------------	------------------


# ITERATED DESIGN




3* credits	76.0 % sDA <sub>300/50%</sub>	3.9 % ASE <sub>1000,250</sub>	506 avg lux	86.5 % blinds open
---------------	----------------------------------	----------------------------------	----------------	-----------------------








ORIGINAL




ITERATED WITH SKYLIGHTS







ORIGINAL GLAZED CURTAIN WALL




LOWER OPAQUE WALL SECTION ADDED



VIEW PLACEMENT




NO BALCONY




8' BALCONY





ORIGINAL



ITERATED

Zone Settings

Loads

Conditioning

Envelope

Settings

Medium Office

Program

PublicAssembly

UseType

People

On

0.0538004648360162

People Density [P/m<sup>2</sup>]

1.2

Metabolic Rate [met]

OfficeMedium BLDG\_OCC\_SCH

Occupancy Schedule

AirSpeed 0

Airspeed Schedule [m/s]

Dynamic Clothing Model ASHRAE55

Clothing [clo]

Equipment

On

7.42446414737023

Equipment Power Density [W/m<sup>2</sup>]

OfficeMedium BLDG\_EQUIP\_SCH\_2013

Equipment Availability Schedule

Lighting

On

6.88645949901007

Lighting Power Density [W/m<sup>2</sup>]

OfficeMedium BLDG\_LIGHT\_SCH\_2013

Lights Availability Schedule

376.603253852113

Illuminance Target [Lux]

Off

DimmingType

Hot Water

On

3

COP [unitless]

10

Inlet Water Temperature [°C]

60

Water Supply Temperature [°C]

OfficeMedium BLDG\_SWH\_SCH

Water Schedule

0.000416395378768378

Flow Rate Per Person [m3/h/P]

Zone Settings

Loads

Conditioning

Envelope

Settings

Heating

On

OfficeMedium HTGSETP\_SCH\_YES\_OPTIMUM

Schedule

HeatAvailNYC5985

HeatingSchedule [Schedule name]

30

Max Heat Supply Air Temp [°C]

NoLimit

HeatingLimitType [enum]

100

MaxHeatingCapacity [W/m<sup>2</sup>]

100

MaxHeatFlow [m<sup>3</sup>/s/m<sup>2</sup>]

0.81

HeatingCOP

Cooling

On

OfficeMedium CLGSETP\_SCH\_YES\_OPTIMUM

Schedule

CoolAvailNYC5985

CoolingSchedule [Schedule name]

18.33333333333333

Min Cool Supply Air Temp [°C]

NoLimit

CoolingLimitType [enum]

100

MaxCoolingCapacity [W/m<sup>2</sup>]

100

MaxCoolFlow [m<sup>3</sup>/s/m<sup>2</sup>]

3.4

CoolingCOP

Humidity Control

Off

Mechanical Ventilation

On

0

Min Fresh Air Person [L/s/p]

0.431646861649681

Min Fresh Air Area [L/s/m<sup>2</sup>]

MechVentAvailNYC5985

MechVentSchedule [Schedule name]

Enthalpy

Heat Recovery Type [enum]

0.7

Heat Recovery Efficiency Sensible [0-1]

0.5

Heat Recovery Efficiency Latent [0-1]

NoEconomizer

Economizer Type [enum]

☐

Turn On EMS Fan Energy

1000

Fan Pressure Rise [Pa]

Natural Ventilation

On

22

Nat Vent SetPoint [°C]

NatVentAvailNYC5985

Natural Ventilation Schedule

0

Nat Vent Min Out Air Temp [°C]

30

Nat Vent Max Out Air Temp [°C]

90

Nat Vent Max Relitive Hum [RH%]

Natural Ventilation

☒ Stack Driven Flow
☐ Crossventilation

Zone Settings

Loads

Conditioning

Envelope

Settings

Constructions

Roof: PHROOF\_UVal\_0.2\_Mass

U-Value[W/(m<sup>2</sup>·K)] = 0.057 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 483.432

Facade: 413.PH4a.ExtWall

U-Value[W/(m<sup>2</sup>·K)] = 0.111 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 472.379

Partition: A413.1960.Partition

U-Value[W/(m<sup>2</sup>·K)] = 2.672 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 521.208

Slab: MediumOffice-4A\_INT-FLOOR-TOPSIDE

U-Value[W/(m<sup>2</sup>·K)] = 1.577 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 190.451

External Floor: 413.PH4a.ExtWall

U-Value[W/(m<sup>2</sup>·K)] = 0.111 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 472.379

Ground Slab: 90.1-2019 Nonresidential CZ 4 Ground Slab (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.692 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 472.04

Ground Wall: 90.1-2019 Nonresidential CZ 4 Ground Wall (Mass)

U-Value[W/(m<sup>2</sup>·K)] = 0.117 | Thermal Capacitance[kJ/K/m<sup>2</sup>] = 476.67

Additional Internal Mass

Off

Infiltration

On

Flow / Exterior Area

0.000299613703968602

InfiltrationFlowExtArea [m3/s/m2]

Advanced Options...

☐

Foundation


FCFactor

0.730023903177162


FFactor [W/m-K]

1.13636363636364

CFactor [W/m2K]



1960 ENV .25cfm/sf



90.1 ENVELOPE




NECB GLAZING



90.1 TEMPLATE




DAYLIGHT DESIGN



NATURAL  
VENTILATION



ALL ELECTRIC/  
HWHP/ LPD  
PH ENVELOPE




PH SUBSLAB INSUL




HI PERF GLAZING



IDEAL INFILTRATION



1960 ENV .25cfm/sf



IDEAL INFILTRATION

**ITERATED SITE EUI IS 7% OF THE BASELINE**







# SITE ENERGY PRODUCTION

## Photovoltaics (PV)

The screenshot displays the PV module interface, which is divided into several sections:

- Input Geometry:** Includes fields for "Pv Panels" (highlighted with a red circle), "Shading Context", "Switch", and "Building Gross SF" (set to 434).
- System design:** Features a "PV Panel" component with settings for "Surf", "Eff", "Area", "Model", "PV", "CSV", "Run", and "Settings". A "TOTAL" label shows "TOTAL SITE EUI (kBtu/yr)" with a value of "20" (circled in red).
- Results:** Includes a "Color panels by output" section with a "Cluster" component and a "Preview" button. A "Toggle" switch is set to "False".
- Monthly electricity generated:** A line graph showing "Solar [kBTU]" over 12 months. The graph has two data series: "Panel 0" (orange line) and "Panel 1" (blue line). The y-axis ranges from 0 to 18,000 kBTU. The x-axis ranges from 1 to 12 months.
- 3D Model:** A 3D rendering of a building with a green roof, showing the placement of PV panels. Red arrows point from the "Pv Panels" input field and the "TOTAL" label to the 3D model.

[illegible]

# CONCLUSIONS AND NEXT STEPS

Successful prototype.

Plan to expand.



Search

37 °F

Clarke Snell

@ArchitecturalSimulation · 110 subscribers · 175 videos

Videos on technical architecture. Current focus is teaching performance simulation in Rhin... >

Customize channelManage videos

HomeVideosShortsPlaylistsCommunity

Created playlists

Sort by

1 video

NYIT.24s. Random Simulation Questions

View full playlist

1 video

NYIT.A222.24S. CLASS VIDS

View full playlist

10 videos

NYIT.ARCHSIM. APPLIED SIMS SUMMARY VIDS

View full playlist

1 video

NYIT.ARCHSIM. Grad Research

View full playlist

11 videos

NYIT.ARCHSIM.THERMAL VIDS

View full playlist

27 videos

NYIT.ARCHSIM. CLARIFICATIONS,...

View full playlist

2 videos

NYIT.A221. Class Vids

View full playlist

7 videos

NYIT.A222. Class Vids

View full playlist

11 videos

NYIT.A325. Class Vids

View full playlist

17 videos

NYIT.A324. Class Vids

View full playlist

11 videos

NYIT.ARCHSIM. EXERCISE VIDS

View full playlist

2 videos

NYIT.ARCHSIM. CONTEXT VIDS

View full playlist

1 video






NYIT.ARCH413. DEV - DAYLIGHTING WORKFLOW

View full playlist

5 videos

NYIT.ARCH 413. DEV - THERMAL ANALYSIS...

View full playlist





CLARKE SNELL, RA  
ASSOCIATE PROFESSOR OF ARCHITECTURE  
DEPARTMENT OF ARCHITECTURE AND DESIGN  
NEW YORK INSTITUTE OF TECHNOLOGY

CLARKESNELL.COM  
FSNELL@NYIT.EDU